



## ecology and environment, inc.

300 McGAW DRIVE, RARITAN CENTER, 2ND FLOOR, EDISON, NEW JERSEY 08817, TEL. 201-225-9659

International Specialists in the Environmental Sciences

October 31, 1980

Mr. Fred N. Rubel  
Chief, Emergency Response and  
Hazardous Materials Inspection Branch  
U.S. EPA Region II  
Woodbridge Ave.  
Edison, N.J. 08817

Subject: SPCC Inspection, Lancia Oil Co., Hackensack, New  
Jersey

Dear Mr. Rubel:

In accordance with Technical Direction Document 2-8009-21, an SPCC inspection was conducted at the Lancia Oil Co. facility, Hackensack, New Jersey, on October 15, 1980. Attached please find the SPCC inspection checklist form for this facility and the appropriate referral letter to Enforcement.

  
Kerry T. Webster

Enclosure  
KTW/djs

235216



SPCC PLAN CHECKLISTDate of Investigation: Oct. 15, 1980Time of Investigation 1100

- 1) Facility Name: Lancia Oil Co., Inc. 1a) Owner: Same as #1  
 2) Location 340 South River Road 1b) Operator: Same as 1a  
Hackensack, N.J. 1c) Telephone: 201-342-5454  
 3) Classification of facility: Marketing Types of Oil: #2 fuel oil  
& Bulk Storage  
 3.5) Is certified SPCC plan available: No  
 4) Nearest navigable water: Hackensack  
River  
 5) Spill history indicated (for previous 12 months): None indicated  
 6) Responsible official: Ugo Lancia  
 7) Management official: Same as 6  
 8) P.E. certification: None Date: n/a  
 9) Does plan consider:  
 a. Prediction of potential spills No plan  
 b. Facility drainage.....  
 c. Topo maps.....  
 d. Containment of bulk storage....  
 e. Facility for transfer operation  
 f. Proper security.....  
 g. Inspection & records procedure  
 h. Training.....  
 9.5) Implementation  
 10) Does plan require construction of additional facilities? n/a  
 If so, is it discussed in plan (including schedule) \_\_\_\_\_  
 Construction complete \_\_\_\_\_  
 11) Storage capacity: (Total) 1.5 million gal. 11a) Above grade X  
 11b) Below grade \_\_\_\_\_  
 12) Number of hours facility is manned: 10 hrs/6 days week  
 13) NPDES Permit No. n/a  
 14) Coast Guard Manual n/a  
 15) Operator's Comments: \_\_\_\_\_

General Appraisal: \_\_\_\_\_

Recommendation: Facility advised to develop an SPCC plan.Signature of Investigator: Kerry T. WebsterDate: October 31, 1980